



RfG (requirements for generators), articles 13-28

Krav fastsat i henhold til EU-forordning 2016/631 – Requirements for grid connection of Generators (RfG)

TEKST	VERSION	DATO
Krav godkendt af Forsyningstilsynet	1	24.09.2018

Art. nr.	Art. stk.	Art. afsn.	Art. enh.	Artikel emne
General requirements for type A power-generating modules				
5	2			<p>Power-generating modules within the following categories shall be considered as significant:</p> <p>(a) connection point below 110 kV and maximum capacity of 0,8 kW or more (type A);</p> <p>(b) connection point below 110 kV and maximum capacity at or above a threshold proposed by each relevant TSO in accordance with the procedure laid out in paragraph 3 (type B). This threshold shall not be above the limits for type B power-generating modules contained in Table 1;</p> <p>(c) connection point below 110 kV and maximum capacity at or above a threshold specified by each relevant TSO in accordance with paragraph 3 (type C). This threshold shall not be above the limits for type C power-generating modules contained in Table 1; or</p> <p>(d) connection point at 110 kV or above (type D). A power-generating module is also of type D if its connection point is below 110 kV and its maximum capacity is at or above a threshold specified in accordance with paragraph 3. This threshold shall not be above the limit for type D power-generating modules contained in Table 1.</p>